



Recreational Water Inspection Report

Establishment Information	
Facility Name COUNTRY INN & SUITES - INDOOR POOL	Facility Type Indoor Pool
Facility ID # CDRY-ALYUD9	Facility Telephone # 608 781-5100
Facility Address 2110 ROSE LA CROSSE , WI 54603-2003	
Licensee Name PRIDE HOTELS LLC	Licensee Address 2110 ROSE ST LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	3.8
Combined Chlorine	0.8
Oxidation Reduction Potential	
Disinfectant Type	Chlorine-Liquid
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	7.4
Alkalinity	60
Cyanuric Acid	
Temperature	83
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	65
Pressure Gauges Reading(s)	18
Turnover Rate	4.46

Inspection Information		
Inspection Type Routine	Inspection Date February 20, 2020	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations

Total # 2

Observed Violations - 31 - General maintenance, walls, ceilings, floors, hosing spectator area separated, maintained, no hazardous conditions, adequate lighting accessibility, solid waste, garbage storage and disposal.

OBSERVATION: Deck drains have patches.

CORRECTIVE ACTION(S): Contact a pool company for assistance and information for proper drain cover repair and maintain all equipment pursuant to ATCP 76.33(1)(e). We will discuss after information is received. Correct By: 20-Feb-2020

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (e) Equipment. Pool equipment, including equipment on the deck, shall be properly located and installed and maintained and repaired as necessary.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: (CORRECTED DURING INSPECTION): The emergency numbers are not correct posted near the designated emergency phone.

CORRECTIVE ACTION(S): Temporary sign posted. Phone will be changed to a direct dial outside line. Correct By: 20-Feb-2020

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.02 (2).

Comments:

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian



Kim Steinberg



Doug Schaefer
(608) 785-9679



Recreational Water Inspection Report

Establishment Information	
Facility Name COUNTRY INN & SUITES - INDOOR WHIRLPOOL	Facility Type Additional Indoor Pool
Facility ID # CDRY-ALYUG2	Facility Telephone # 608 781-5100
Facility Address 2110 ROSE LA CROSSE , WI 54603-2003	
Licensee Name PRIDE HOTELS LLC	Licensee Address 2110 ROSE ST LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	3.0
Combined Chlorine	0.8
Oxidation Reduction Potential	
Disinfectant Type	Chlorine-Liquid
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	7.2
Alkalinity	30
Cyanuric Acid	
Temperature	101
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	40
Pressure Gauges Reading(s)	22
Turnover Rate	0.48

Inspection Information		
Inspection Type Routine	Inspection Date February 20, 2020	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations

Total # 3

Observed Violations - 16 - pH alkalinity within limits or balanced, Cyanuric acid - within limits, Superoxidation - done as needed.

OBSERVATION: (CORRECTED DURING INSPECTION): The total alkalinity is 30ppm.

CORRECTIVE ACTION(S): Maintain the total alkalinity between 60 and 180 ppm. Sodium bicarbonate added. Correct By: 20-Feb-2020

CODE CITATION: ATCP 76.14 Disinfectant feeding and residuals. (4) CHEMICAL CONCENTRATIONS AND RESIDUALS. (d) Alkalinity. The total alkalinity of pool water shall be maintained between 60 and 180 ppm as calcium carbonate unless it can be shown that another level of total alkalinity produces chemically balanced water based on calculations approved by the department.

Observed Violations - 31 - General maintenance, walls, ceilings. floors, hosing spectator area separated, maintained, no hazardous conditions, adequate lighting accessibility, solid waste, garbage storage and disposal.

OBSERVATION: Deck drain covers have been patched.

CORRECTIVE ACTION(S): Contact a pool company for information on proper repair to maintain all equipment pursuant to ATCP 76.33(1)(e). We will discuss after information is received.

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (e) Equipment. Pool equipment, including equipment on the deck, shall be properly located and installed and maintained and repaired as necessary.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: (CORRECTED DURING INSPECTION): The emergency numbers posted are not correct near the designated emergency phone.

CORRECTIVE ACTION(S): Post the emergency numbers near the designated emergency phone. Temporary sign posted and phone will be changed to a direct dial outside line.

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.02 (2).

Comments:

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian



Kim Steinberg



Doug Schaefer
(608) 785-9679