



Recreational Water Inspection Report

<b>Establishment Information</b>	
Facility Name GUNDERSEN LUTHERAN - SPORTS MEDICINE	Facility Type Indoor Pool
Facility ID # ASTS-8NVSRM	Facility Telephone # 608 775-8600
Facility Address 3100 KINNEY COULEE RD S ONALASKA , WI 54650	
Licensee Name GUNDERSEN HEALTH SYSTEMS	Licensee Address 1836 SOUTH AVE LA CROSSE , WI 54601

<b>Pool Parameters</b>	
Free Available Chlorine/Bromine	12
Combined Chlorine	
Oxidation Reduction Potential	
Disinfectant Type	Bromine
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	7.4
Alkalinity	70
Cyanuric Acid	
Temperature	92
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	45
Pressure Gauges Reading(s)	12
Turnover Rate	1.2

<b>Inspection Information</b>		
Inspection Type Routine	Inspection Date April 8, 2019	Total Time Spent

**OPERATOR** - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

**Observed Violations**

**Total # 1**

**Observed Violations - 29 - Facility maintenance and equipment - Pool and deck area - good repair, sanitation, maintained, depth markings, boundary line, drinking fountain**

**OBSERVATION:** The deck is not sanitized weekly.

**CORRECTIVE ACTION(S):** Clean and sanitize the deck and appurtenances according to ATCP 76.33 (1)(b). Correct By: 15-Apr-2019

**CODE CITATION:** ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (b) Deck maintenance and cleaning. Pool areas and appurtenances, including safety pads, shall be maintained in good repair and shall be rinsed daily to prevent microbial growth. Indoor pool decks shall be disinfected at least weekly. Depth markings along the edge of the pool shall be maintained to be clearly visible and readable. The deck shall be kept unobstructed except for easily portable furniture and equipment.

**Comments:**

Contact Sam (785-9732) with questions. Suggest contacting pool professionals to adjust/calibrate the ORP controller.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



**Marion Pahl**

Sanitarian



**Samuel Welch**  
**(608) 785-9732**