



Recreational Water Inspection Report

Establishment Information	
Facility Name HOLIDAY INN EXPRESS - ONALASKA	Facility Type Indoor Pool
Facility ID # MWAS-AZRJFV	Facility Telephone # 608 783-6555
Facility Address 9409 STATE ROAD 16 ONALASKA , WI 54650	
Licensee Name SOMONA EAST LLC	Licensee Address PO BOX 423 VERMILLION , SD 57069

Pool Parameters	
Free Available Chlorine/Bromine Combined Chlorine	6.25
Oxidation Reduction Potential	800
Disinfectant Type	Bromine
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	7.8
Alkalinity	220
Cyanuric Acid	
Temperature	82
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	75
Pressure Gauges Reading(s)	15
Turnover Rate	3.11

Inspection Information		
Inspection Type Routine	Inspection Date September 5, 2019	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 1</p> <p>Observed Violations - 16 - pH alkalinity within limits or balanced, Cyanuric acid - within limits, Superoxidation - done as needed.</p> <p>OBSERVATION: The total alkalinity is 220 ppm.</p> <p>CORRECTIVE ACTION(S): Maintain the total alkalinity between 60 and 180 ppm. Correct By: 05-Sep-2019</p> <p>CODE CITATION: ATCP 76.14 Disinfectant feeding and residuals. (4) CHEMICAL CONCENTRATIONS AND RESIDUALS. (d) Alkalinity. The total alkalinity of pool water shall be maintained between 60 and 180 ppm as calcium carbonate unless it can be shown that another level of total alkalinity produces chemically balanced water based on calculations approved by the department.</p>

Comments:

See swimming pool inspection report for additional corrections required. Contact Sam (785-9732) or Amanda (785-3438) when corrected or with questions. VGBA compliance and drain cover documentation are on hand.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



Tim Klinger

Sanitarian



Samuel Welch
(608) 785-9732



Recreational Water Inspection Report

Establishment Information	
Facility Name HOLIDAY INN EXPRESS - ONALASKA	Facility Type Additional Indoor Pool
Facility ID # MWAS-AZRJJ6	Facility Telephone # 608 783-6555
Facility Address 9409 STATE ROAD 16 ONALASKA , WI 54650	
Licensee Name SOMONA EAST LLC	Licensee Address PO BOX 423 VERMILLION , SD 57069

Pool Parameters	
Free Available Chlorine/Bromine Combined Chlorine	12.5
Oxidation Reduction Potential	825
Disinfectant Type	Bromine
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	7.6
Alkalinity	120
Cyanuric Acid	
Temperature	100
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	45
Pressure Gauges Reading(s)	8
Turnover Rate	.37

Inspection Information		
Inspection Type Routine	Inspection Date September 5, 2019	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 7</p> <p>Observed Violations - 11 - Chemicals - proper labeling and storage, no mixing of chemicals, smoking prohibited OBSERVATION: The working container of muriatic acid is not labeled according to ATCP 76.12(1). CORRECTIVE ACTION(S): Label the chemical container according to ATCP 76.12(1). Correct By: 05-Sep-2019 CODE CITATION: ATCP 76.12 Labeling, storing, mixing, and handling chemicals. (1) LABELING. Except for erosion feeders, which require only the name of the chemical, all chemicals used in the operation and maintenance of pools, and bulk storage tanks containing the chemicals, shall be conspicuously labeled with the following information: (a) Name of the product. (b) The manufacturer's name and address. (c) Active ingredients. (d) Directions for use.</p>

- (e) Hazardous ingredient warning.
- (f) The U.S. environmental protection agency registration number.

Observed Violations - 11 - Chemicals - proper labeling and storage, no mixing of chemicals, smoking prohibited

OBSERVATION: Chemicals are not stored in accordance with ATCP 76.12(2). Gallon bottles of shock are stored above the muriatic acid container in the mechanical room.

CORRECTIVE ACTION(S): Store chemicals in accordance with ATCP 76.12(2). Correct By: 05-Sep-2019

CODE CITATION: ATCP 76.12 Labeling, storing, mixing, and handling chemicals. (2) STORAGE. Chemicals shall be stored in the original or a properly-labeled container, which shall be covered and kept in a clean, dry, well ventilated and locked area away from flammables, incompatible chemicals, and heat sources. Only authorized personnel shall have access to the storage area. Chemicals may not be stored in chlorine gas storage areas. Food may not be stored in the chemical storage area. Smoking is prohibited in the chemicals storage area.

Observed Violations - 13 - Approved design, data plate, intertwined with recirculation pump

This is a Critical violation

OBSERVATION: The acid feeder pump is not electrically connected to the recirculation pump control circuit.

CORRECTIVE ACTION(S): Electrically connect the feeder to the recirculation pump so it cannot keep running when the recirculation pump is turned off. Correct By: 05-Oct-2019

CODE CITATION: ATCP 76.13 All disinfectant feeders shall be approved by the department of commerce and installed according to the manufacturer's directions and used only with the disinfectant recommended by the manufacturer and meet all of the following requirements:

(c) Feeder pumps shall be electrically connected to the recirculation pump control circuit and have a separate disconnect switch.

Observed Violations - 31 - General maintenance, walls, ceilings, floors, hosing spectator area separated, maintained, no hazardous conditions, adequate lighting accessibility, solid waste, garbage storage and disposal.

OBSERVATION: The circular floor drains on the pool deck are not being maintained and repaired as necessary.

CORRECTIVE ACTION(S): Repair and maintain all equipment pursuant to ATCP 76.33(1)(e). Correct By: 05-Oct-2019

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (e) Equipment. Pool equipment, including equipment on the deck, shall be properly located and installed and maintained and repaired as necessary.

Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.

OBSERVATION: "NO DIVING" is not posted in 4" letters.

CORRECTIVE ACTION(S): Post signage in compliance with ATCP 76.29(1)(c). Correct By: 05-Oct-2019

CODE CITATION: ATCP 76.29 Posting pool and water attraction rules. (1) GENERAL. (c) A pool that is 200 square feet in area or greater that does not have an approved diving well configuration shall have "NO DIVING" signs in at least 4-inch high letters included with the rules listed under par. (b).

Observed Violations - 29 - Facility maintenance and equipment - Pool and deck area - good repair, sanitation, maintained, depth markings, boundary line, drinking fountain

OBSERVATION: The drinking fountain is not present.

CORRECTIVE ACTION(S): Replace the drinking fountain (suggest in hallway as discussed.) Correct By: 05-Oct-2019

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (g) Drinking fountain. Each drinking fountain required under s. SPS 390.19 shall be maintained in clean and sanitary condition.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: The emergency numbers and facility location directions are not posted near the designated emergency phone.

CORRECTIVE ACTION(S): Post the emergency numbers and facility location directions near the designated emergency phone. Correct By: 05-Sep-2019

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.02 (2).

Comments:

Contact Sam (785-9732) or Amanda (785-3438) when corrected or with questions. VGBA and drain cover documentation on hand.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



Tim Klinger

Sanitarian



Samuel Welch
(608) 785-9732