



### Recreational Water Inspection Report

| <b>Establishment Information</b>   |  |
|--|--|
| Facility Name<br><b>ONALASKA COMFORT INN</b>                               | Facility Type<br><b>Indoor Pool</b>                                    |
| Facility ID #<br><b>MWAS-ATLLNE</b>  | Facility Telephone #<br><b>608 412-3619</b>                            |
| Facility Address<br><b>1223 CROSSING MEADOW DR<br/>ONALASKA , WI 54650</b> |  |
| Licensee Name<br><b>JBT HOTELS LLL</b>                                     | Licensee Address<br><b>1912 FANELL DR<br/>LA CROSSE , WI<br/>54601</b> |

| <b>Pool Parameters</b>          |                 |
|---------------------------------|-----------------|
| Free Available Chlorine/Bromine | 2.0             |
| Combined Chlorine               | 0.2             |
| Oxidation Reduction Potential   | 780             |
| Disinfectant Type               | Chlorine-Liquid |
| Secondary Disinfectant Type     |                 |
| Secondary Disinfectant Level    |                 |
| pH                              | 7.4             |
| Alkalinity                      | 80              |
| Cyanuric Acid                   |                 |
| Temperature                     | 83.7            |
| Calcium Hardness                |                 |
| Saturation Index                |                 |
| Flowmeter Reading(s)            | 55              |
| Pressure Gauges Reading(s)      |                 |
| Turnover Rate                   | 3.44            |

| <b>Inspection Information</b> |                                     |                  |
|-------------------------------|-------------------------------------|------------------|
| Inspection Type<br>Routine    | Inspection Date<br>January 16, 2020 | Total Time Spent |

**OPERATOR** - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

**Observed Violations**

**Total # 1**

**Observed Violations - 28 - Fecal accident records, D-I-I reporting as required, and other reports as required, maintained, accurate, and accessible.**

**OBSERVATION:** Pump performance curve is not available for review.

**CORRECTIVE ACTION(S):** Keep records in accordance with ATCP 76.32(3). Correct By: 16-Jan-2020

**CODE CITATION:** ATCP 76.32 Monthly reports and records. (3) FILES. (a) The operator shall maintain on the premises a file containing a copy of each of the following:

1. The monthly operating reports required under sub. (1).
  2. Each laboratory bacteriological report.
  3. Each fecal accident report made under s. ATCP 76.31.
  4. In addition to the reports listed under subs. 1., 2., and 3. any other report submitted to the department or agent for the preceding 2 year period.
  5. A copy of the most current version of ch. ATCP 76.
  6. Pool construction plans.
  7. The manufacturer's pump performance curve, manual of instruction on filter operation, recommendations for operation and maintenance of all equipment, and instructions and other pertinent information on pool operation and maintenance.
  8. The most recent Federal centers for disease control recommendations for fecal accidents or other plan in response to fecal accidents.
  9. Daily inspections and operational tests as specified in s. ATCP 76.37.
- (b) All records shall be kept at least 7 years, except that monthly reports, fecal accident reports, daily inspection results, and operational tests shall be kept for at least 2 years.
- (c) All of the documents under par. (a) shall be accessible to the operator and the department or agent.

**Comments:**

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian



**Jamie Turner**



**Amanda Ramos**  
**(608) 785-9771**