



LA CROSSE COUNTY

Recreational Water Inspection Report

Establishment Information	
Facility Name SAINT ROSE CONVENT	Facility Type Indoor Pool
Facility ID # HSAT-7QWKXF	Facility Telephone # 608 791-5273
Facility Address 715 9TH ST S LA CROSSE , WI 54601	
Licensee Name FRANCISCAN SISTERS	Licensee Address PERPETUAL ADORATION 912 MARKET ST LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	5.8
Combined Chlorine	0
Oxidation Reduction Potential	
Disinfectant Type	Chlorine-Liquid
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	7.2
Alkalinity	130
Cyanuric Acid	
Temperature	90
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	60
Pressure Gauges Reading(s)	12
Turnover Rate	

Inspection Information		
Inspection Type Routine	Inspection Date January 30, 2019	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Comments:

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian

Randy Hager

Aron Newberry
(608) 785-9730



LA CROSSE COUNTY

Recreational Water Inspection Report

Establishment Information	
Facility Name SAINT ROSE CONVENT	Facility Type Additional Indoor Pool
Facility ID # HSAT-7QXD23	Facility Telephone # 608 791-5271
Facility Address 715 9TH ST S LA CROSSE , WI 54601	
Licensee Name FRANCISCAN SISTERS	Licensee Address PERPETUAL ADORATION 912 MARKET ST LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	6.2
Combined Chlorine	0
Oxidation Reduction Potential	
Disinfectant Type	Chlorine-Liquid
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	7.2
Alkalinity	160
Cyanuric Acid	
Temperature	101
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	55
Pressure Gauges Reading(s)	15
Turnover Rate	

Inspection Information		
Inspection Type Routine	Inspection Date January 30, 2019	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.


Comments:

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian


Randy Hager


Aron Newberry
(608) 785-9730