



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name ST VALLERIES APTS	Facility Type Outdoor Pool
Facility ID # HSAT-7QX2DJ	Facility Telephone # 608 788-4306
Facility Address 4445 MORMON COULEE RD LA CROSSE , WI 54601	
Licensee Name PARAMARK CORP	Licensee Address PO BOX 249 ROCHESTER , MN 55903 -0249

Pool Parameters	
Free Available Chlorine/Bromine	5.2
Combined Chlorine	0
pH	7.2
Alkalinity	
Cyanuric Acid	
Temperature	84.4
Flowmeter Reading(s)	75
Pressure Gauges Reading(s)	22

Inspection Information		
Inspection Type Routine	Inspection Date June 20, 2017	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations

Total # 4

Observed Violations - 20 - Approved test kits available, maintained, used, frequency of testing - 2X/day-pools, 4x/day-whirlpools alkalinity, cyanuric acid, and combined chlorine done as required.

OBSERVATION: The test kit used by the facility has not been approved by the department.

CORRECTIVE ACTION(S): Replace the test kit with one from the approved list. Correct By: 27-Jun-2017

CODE CITATION: ATCP 76.17 Water test kits. (1) A test kit of a type approved by the department shall be maintained for testing the pool water pH; the disinfectant residual; the combined chlorine level, when chlorine is used; the total alkalinity; and the cyanuric acid concentration, when used.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: No biohazard safety kit is located on the premises.

CORRECTIVE ACTION(S): Provide a biohazard safety kit at the first aid station. Correct By: 27-Jun-2017

CODE CITATION: ATCP 76.27 First aid supplies. (2) Biohazard safety equipment, including a blood and biohazard disposal kit shall be located at the first aid station or another location on the premises approved by the department.

Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.

OBSERVATION: The letters on the pool rules signage are less than 1-inch in height.

CORRECTIVE ACTION(S): Reprint the sign in compliance with ATCP 76.29(1)(b). Correct By: 28-Jul-2017

CODE CITATION: ATCP 76.29 Posting pool and water attraction rules. (1) GENERAL. (b) A legible sign showing pool use rules shall be posted in a conspicuous place or places in the pool area. The sign shall include at least all of the rules in this paragraph in letters at least one inch high. Pool rules in connection with water attractions, therapy pools or other specialized pools defined in s. Comm 90 or this chapter may not be eliminated or modified without approval by the department.

1. Do not enter the pool if you have a communicable disease or an open cut.
2. Do not bring food, drink, gum or tobacco into the pool.
3. Shower before entering the pool and after use of toilet facilities.
4. Do not run or engage in rough play in the pool area.
5. Do not bring animals into the pool area.
6. Diaper changing on the pool deck is prohibited.
7. Glass and shatterable items are prohibited in the pool area.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: CPR face mask are missing from the first aid kit.

CORRECTIVE ACTION(S): Provide all the items listed in ATCP 76.27(1) in the first aid kit. Correct By: 27-Jun-2017

CODE CITATION: ATCP 76.27 First aid supplies. (1) A first aid kit of a sort approved by the department and 2 durable blankets in good condition shall be available at each pool area. The first aid kit shall contain all of the following items:

1. Gauze pads - 4" x 4", 2. Gauze pads - 8" x 10", 3. Adhesive bandages, 4. Triangular bandages, 5. Scissors, 6. Gauze roller bandage, 7. Tweezers, 8. Adhesive tape, 9. Eye wash, 10. Elastic bandage, 11. Disposable surgical gloves, 12. Resuscitation pocket face mask, 13. Instant cold packs.

Comments:

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian

**Aron Newberry
(608) 785-9730**