



Recreational Water Inspection Report

| Establishment Information | |
|--|--|
| Facility Name BRONSTON CHIROPRACTIC | Facility Type Indoor Pool |
| Facility ID # HSAT-7QXFZF | Facility Telephone # 608 782-2225 |
| Facility Address 1122 SAINT ANDREW ST LA CROSSE , WI 54603 | |
| Licensee Name BRONSTON LEO | Licensee Address 1202 COUNTY RD PH SUITE 100 ONALASKA , WI 54650 |

| Pool Parameters | |
|--|---------|
| Free Available Chlorine/Bromine Combined Chlorine | 12.5 |
| Oxidation Reduction Potential | |
| Disinfectant Type | Bromine |
| Secondary Disinfectant Type | |
| Secondary Disinfectant Level | |
| pH | 7.4 |
| Alkalinity | 180 |
| Cyanuric Acid | |
| Temperature | 92 |
| Calcium Hardness | |
| Saturation Index | |
| Flowmeter Reading(s) | |
| Pressure Gauges Reading(s) Turnover Rate | |

| Inspection Information | | |
|-------------------------------|----------------------------------|------------------|
| Inspection Type Routine | Inspection Date June 26, 2019 | Total Time Spent |

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations

Total # 5

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: The emergency telephone does not work.

CORRECTIVE ACTION(S): Provide a functional emergency telephone immediately. Correct By: 26-Jun-2019

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.02 (2).

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: A first aid kit is not available in the pool area.

CORRECTIVE ACTION(S): Provide a first aid kit in the pool area. Correct By: 26-Jun-2019

CODE CITATION: ATCP 76.27 First aid supplies. (1) A first aid kit of a sort approved by the department and 2 durable blankets in good condition shall be available at each pool area. The first aid kit shall contain all of the following items:

1. Gauze pads - 4" x 4",
2. Gauze pads - 8" x 10",
3. Adhesive bandages,
4. Triangular bandages,
5. Scissors,
6. Gauze roller bandage,
7. Tweezers,
8. Adhesive tape,
9. Eye wash,
10. Elastic bandage,
11. Disposable surgical gloves,
12. Resuscitation pocket face mask,
13. Instant cold packs.

Observed Violations - 29 - Facility maintenance and equipment - Pool and deck area - good repair, sanitation, maintained, depth markings, boundary line, drinking fountain

OBSERVATION: The pool basin is in need of cleaning.

CORRECTIVE ACTION(S): Keep the facility in a clean condition pursuant to ATCP 76.33(1)(a). Correct By: 03-Jul-2019

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (a) General. Each pool shall be routinely brushed or vacuumed to keep the basin and surrounding appurtenances free of sediment, lint, hair, debris, algae and slime growth and discoloration. Cracks or other defects shall be repaired and the pool interior shall be refinished as necessary to maintain it in a cleanable condition. The pool and water area shall be maintained in a clean and sanitary condition. Glass and shatterable plastic items shall be prohibited in the pool area.

Observed Violations - 29 - Facility maintenance and equipment - Pool and deck area - good repair, sanitation, maintained, depth markings, boundary line, drinking fountain

OBSERVATION: The pool basin is pitted or damaged.

CORRECTIVE ACTION(S): Repair the pool basin so it is finished and easily cleanable. Correct By: 26-Jun-2020

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (a) General. Each pool shall be routinely brushed or vacuumed to keep the basin and surrounding appurtenances free of sediment, lint, hair, debris, algae and slime growth and discoloration. Cracks or other defects shall be repaired and the pool interior shall be refinished as necessary to maintain it in a cleanable condition. The pool and water area shall be maintained in a clean and sanitary condition. Glass and shatterable plastic items shall be prohibited in the pool area.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: The emergency numbers and facility location directions are not posted near the designated emergency phone.

CORRECTIVE ACTION(S): Post the emergency numbers and facility location directions near the designated emergency phone. Correct By: 26-Jun-2019

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.02 (2).

Comments:

Re-inspection after 2 weeks. Contact Sam (785-9732) when corrected or with questions. Broken tiles noted around hatch for pool room. Repair these tiles.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

A re-inspection to assess your correction of these violations will be conducted on, or about, 07/10/2019

Person in Charge



Diana Smith

Sanitarian



Samuel Welch
(608) 785-9732