



Recreational Water Establishment Inspection Report

<b>Establishment Information</b>	
Facility Name COURTYARD BY MARRIOTT	Facility Type Additional Indoor Pool
Facility ID # HSAT-7QX7P5	Facility Telephone # 608 782-1000
Facility Address 500 FRONT ST S LA CROSSE , WI 54601	
Licensee Name RIVERFRONT HOTEL INC	Licensee Address 1934 HENNEPIN AVE S #201 MINNEAPOLIS , MN 55403

<b>Pool Parameters</b>	
Free Available Chlorine/Bromine	7.6
Combined Chlorine	.4
pH	7.2
Alkalinity	60
Cyanuric Acid	NA
Temperature	102
Flowmeter Reading(s)	60
Pressure Gauges Reading(s)	20

<b>Inspection Information</b>		
Inspection Type Routine	Inspection Date January 10, 2018	Total Time Spent

**OPERATOR** - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

<b>Comments:</b>
<a href="#">Current VGBA drains expire on March 5, 2019.</a>

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian

**Bradley Heuser**

**Aron Newberry**  
(608) 785-9730