



Recreational Water Inspection Report

Establishment Information	
Facility Name COZY CORNER COTTAGES	Facility Type Outdoor Pool
Facility ID # ASTS-99RHWL	Facility Telephone # 608
Facility Address W8071 COUNTY RD ZB ONALASKA , WI 54650	
Licensee Name COZY CORNER CABINS LLC	Licensee Address W8071 COUNTY RD ZB ONALASKA , WI 54650

Pool Parameters	
Free Available Chlorine/Bromine	5
Combined Chlorine	.2
pH	7.6
Alkalinity	130
Cyanuric Acid	
Temperature	76
Flowmeter Reading(s)	65
Pressure Gauges Reading(s)	

Inspection Information		
Inspection Type Routine	Inspection Date June 8, 2018	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations

Total # 4

Observed Violations - 29 - Facility maintenance and equipment - Pool and deck area - good repair, sanitation, maintained, depth markings, boundary line, drinking fountain

OBSERVATION: The deck and appurtenances are not being cleaned and sanitized regularly.

CORRECTIVE ACTION(S): Clean and sanitize the deck and appurtenances according to ATCP 76.33 (1)(b). Correct By: 08-Jun-2018

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (b) Deck maintenance and cleaning. Pool areas and appurtenances, including safety pads, shall be maintained in good repair and shall be rinsed daily to prevent microbial growth. Indoor pool decks shall be disinfected at least weekly. Depth markings along the edge of the pool shall be maintained to be clearly visible and readable. The deck shall be kept unobstructed except for easily portable furniture and equipment.

Observed Violations - 34 - Security - pool enclosure, controlled access, self-closing gates and latches access through bathhouse fencing safety rope as required.

OBSERVATION: The door or gate to the pool enclosure is not self-closing or latching.

CORRECTIVE ACTION(S): Repair the door immediately so that it is self-closing and latching. Correct By: 11-Jun-2018

CODE CITATION: ATCP 76.34 Pool design. (4) All pool areas shall be enclosed and have self-closing and latching gates or doors that are lockable.

Observed Violations - 29 - Facility maintenance and equipment - Pool and deck area - good repair, sanitation, maintained, depth markings, boundary line, drinking fountain

OBSERVATION: The pool deck is cracked and settling at the shallow end.

CORRECTIVE ACTION(S): Repair the pool basin so it is finished and easily cleanable. Correct By: 08-Jun-2018

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (a) General. Each pool shall be routinely brushed or vacuumed to keep the basin and surrounding appurtenances free of sediment, lint, hair, debris, algae and slime growth and discoloration. Cracks or other defects shall be repaired and the pool interior shall be refinished as necessary to maintain it in a cleanable condition. The pool and water area shall be maintained in a clean and sanitary condition. Glass and shatterable plastic items shall be prohibited in the pool area.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: The emergency numbers are not posted near the designated emergency phone. Signage is missing address of facility.

CORRECTIVE ACTION(S): Post the emergency numbers near the designated emergency phone. Correct By: 08-Jun-2018

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.


Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.02 (2).

Comments:

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian



Scott Pirnstill



**Doug Schaefer
(608) 785-9679**