



Recreational Water Inspection Report

Establishment Information	
Facility Name DAYS INN LA CROSSE	Facility Type Indoor Pool
Facility ID # ASTS-ADCJ9G	Facility Telephone # 608 783-1000
Facility Address 101 SKY HARBOUR DR LA CROSSE , WI 54603	
Licensee Name TWIN CITY LODGING LLC	Licensee Address 101 SKY HARBOUR DR LA CROSSE , WI 54603

Pool Parameters	
Free Available Chlorine/Bromine	
Combined Chlorine	
pH	
Alkalinity	
Cyanuric Acid	
Temperature	
Flowmeter Reading(s)	
Pressure Gauges Reading(s)	

Inspection Information		
Inspection Type Onsite Visit	Inspection Date June 18, 2018	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 1</p> <p>Observed Violations - 34 - Security - pool enclosure, controlled access, self-closing gates and latches access through bathhouse fencing safety rope as required.</p> <p>OBSERVATION: (CORRECTED DURING INSPECTION): The exterior door to the pool enclosure is blocked open.</p> <p>CORRECTIVE ACTION(S): Repair the door immediately so that it is self-closing and latching.</p> <p>CODE CITATION: ATCP 76.34 Pool design. (4) All pool areas shall be enclosed and have self-closing and latching gates or doors that are lockable.</p>

Comments:

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian



Arun Babu



Doug Schaefer
(608) 785-9679