



Recreational Water Inspection Report

Establishment Information	
Facility Name ECONOLODGE	Facility Type Additional Indoor Pool
Facility ID # ASTS-AE9MNP	Facility Telephone # 608 781-0200
Facility Address 1906 ROSE ST LA CROSSE , WI 54603	
Licensee Name NOBLE HOTELS LLC	Licensee Address 1906 ROSE ST LA CROSSE , WI 54603

Pool Parameters	
Free Available Chlorine/Bromine Combined Chlorine	10
Oxidation Reduction Potential	
Disinfectant Type	Bromine
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	
Alkalinity	140
Cyanuric Acid	
Temperature	101
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	NA
Pressure Gauges Reading(s)	18
Turnover Rate	

Inspection Information		
Inspection Type Routine	Inspection Date February 11, 2020	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 10</p> <p>Observed Violations - 09 - Gauges and flowmeters maintained, operated, accurate, installed, approved pressure or vacuum REPEAT OBSERVATION: The flow meter is not working. CORRECTIVE ACTION(S): Repair or replace the specified equipment so an accurate reading can be recorded. Correct By: 11-Feb-2020 CODE CITATION: ATCP 76.11 Recirculation system. (5) FLOWMETERS, VALVES, AND GAUGES. Flowmeters, valves and gauges shall be maintained in operating condition.</p> <p>Observed Violations - 11 - Chemicals - proper labeling and storage, no mixing of chemicals, smoking prohibited OBSERVATION: Shock is not labeled according to ATCP 76.12(1).</p>

CORRECTIVE ACTION(S): Label the chemical container according to ATCP 76.12(1). Correct By: 11-Feb-2020

CODE CITATION: ATCP 76.12 Labeling, storing, mixing, and handling chemicals. (1) LABELING. Except for erosion feeders, which require only the name of the chemical, all chemicals used in the operation and maintenance of pools, and bulk storage tanks containing the chemicals, shall be conspicuously labeled with the following information:

- (a) Name of the product.
- (b) The manufacturer's name and address.
- (c) Active ingredients.
- (d) Directions for use.
- (e) Hazardous ingredient warning.
- (f) The U.S. environmental protection agency registration number.

Observed Violations - 11 - Chemicals - proper labeling and storage, no mixing of chemicals, smoking prohibited

OBSERVATION: (CORRECTED DURING INSPECTION): Chemicals are not stored in accordance with ATCP 76.12(2). Chemicals stored on top of each other.

CORRECTIVE ACTION(S): Store chemicals in accordance with ATCP 76.12(2).

CODE CITATION: ATCP 76.12 Labeling, storing, mixing, and handling chemicals. (2) STORAGE. Chemicals shall be stored in the original or a properly-labeled container, which shall be covered and kept in a clean, dry, well ventilated and locked area away from flammables, incompatible chemicals, and heat sources. Only authorized personnel shall have access to the storage area. Chemicals may not be stored in chlorine gas storage areas. Food may not be stored in the chemical storage area. Smoking is prohibited in the chemicals storage area.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: No biohazard safety kit is located on the premises.

CORRECTIVE ACTION(S): Provide a biohazard safety kit at the first aid station. Correct By: 04-Feb-2020

CODE CITATION: ATCP 76.27 First aid supplies. (2) Biohazard safety equipment, including a blood and biohazard disposal kit shall be located at the first aid station or another location on the premises approved by the department.

Observed Violations - 05 - Water level maintained, Proportional flow - gutter or skimmers versus drain

OBSERVATION: (CORRECTED DURING INSPECTION): The skimmer to main drain flow ration is not set correctly.

CORRECTIVE ACTION(S): Readjust the flow so that only 20% comes through the main drain and 80% comes through the skimmers.

CODE CITATION: ATCP 76.11 Recirculation system. (2) SKIMMERS AND RECIRCULATION FLOW. (a) The flow through each skimmer shall be adjusted as often as necessary to maintain a vigorous skimming action at each skimmer. The pool water level shall be maintained at an elevation so that continuous effective surface skimming is accomplished through skimmers or over the gutter lip. For gutter pools, approximately 75% of the required recirculation flow shall be through the gutter and 25% through the main drain during normal operation. For pools with skimmers, approximately 80% of the recirculation flow shall be through skimmers and 20% through the main drain. For reverse flow pools, 100% of the required circulation shall be through the gutter or skimmer.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: A first aid kit is not available in the pool area.

CORRECTIVE ACTION(S): Provide a first aid kit in the pool area. Correct By: 11-Feb-2020

CODE CITATION: ATCP 76.27 First aid supplies. (1) A first aid kit of a sort approved by the department and 2 durable blankets in good condition shall be available at each pool area. The first aid kit shall contain all of the following items:
1. Gauze pads - 4" x 4", 2. Gauze pads - 8" x 10", 3. Adhesive bandages, 4. Triangular bandages, 5. Scissors, 6. Gauze roller bandage, 7. Tweezers, 8. Adhesive tape, 9. Eye wash, 10. Elastic bandage, 11. Disposable surgical gloves, 12. Resuscitation pocket face mask, 13. Instant cold packs.

Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.

OBSERVATION: The letters on the pool rules signage are less than 1-inch in height.

CORRECTIVE ACTION(S): Reprint the sign in compliance with ATCP 76.29(1)(b). Correct By: 11-Mar-2020

CODE CITATION: ATCP 76.29 Posting pool and water attraction rules. (1) GENERAL. (b) A legible sign showing pool use rules shall be posted in a conspicuous place or places in the pool area. The sign shall include at least all of the rules in this paragraph in letters at least one inch high. Pool rules in connection with water attractions, therapy pools or other specialized pools defined in s. Comm 90 or this chapter may not be eliminated or modified without approval by the department.

1. Do not enter the pool if you have a communicable disease or an open cut.
2. Do not bring food, drink, gum or tobacco into the pool.

3. Shower before entering the pool and after use of toilet facilities.
4. Do not run or engage in rough play in the pool area.
5. Do not bring animals into the pool area.
6. Diaper changing on the pool deck is prohibited.
7. Glass and shatterable items are prohibited in the pool area.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: 2 durable blankets are not available in the pool area.

CORRECTIVE ACTION(S): Provide 2 durable blankets in the pool area. Correct By: 11-Feb-2020

CODE CITATION: ATCP 76.27 First aid supplies. (1) A first aid kit of a sort approved by the department and 2 durable blankets in good condition shall be available at each pool area. The first aid kit shall contain all of the following items:

1. Gauze pads - 4" x 4", 2. Gauze pads - 8" x 10", 3. Adhesive bandages, 4. Triangular bandages, 5. Scissors, 6. Gauze roller bandage, 7. Tweezers, 8. Adhesive tape, 9. Eye wash, 10. Elastic bandage, 11. Disposable surgical gloves, 12. Resuscitation pocket face mask, 13. Instant cold packs.

Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.

OBSERVATION: The rules are out of date and not current with code.

CORRECTIVE ACTION(S): Provide a sign in compliance with ATCP 76.29(1)(b). Correct By: 11-Feb-2020

CODE CITATION: ATCP 76.29 Posting pool and water attraction rules. (1) GENERAL. (b) A legible sign showing pool use rules shall be posted in a conspicuous place or places in the pool area. The sign shall include at least all of the rules in this paragraph in letters at least one inch high. Pool rules in connection with water attractions, therapy pools or other specialized pools defined in s. SPS 390 or this chapter may not be eliminated or modified without approval by the department.

1. Do not enter the pool if you have a communicable disease or an open cut.
2. Do not bring food, drink, gum or tobacco into the pool.
3. Shower before entering the pool and after use of toilet facilities.
4. Do not run or engage in rough play in the pool area.
5. Do not bring animals into the pool area.
6. Diaper changing on the pool deck is prohibited.
7. Glass and shatterable items are prohibited in the pool area.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: The emergency numbers are not posted near the designated emergency phone.

CORRECTIVE ACTION(S): Post the emergency numbers, address and emergency phone near the designated emergency phone. Correct By: 04-Feb-2020

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.02 (2).

Comments:

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian



Tushar Patel



Doug Schaefer
(608) 785-9679