



Recreational Water Inspection Report

Establishment Information	
Facility Name CAMP EHAWEE	Facility Type Outdoor Pool
Facility ID # BSAW-86PHB8	Facility Telephone # 800 236-2710
Facility Address N9559 WILD RD MINDORO , WI 54644	
Licensee Name GIRL SCOUTS OF WISCONSIN-BADGERLAND INC	Licensee Address 2710 SKI LN MADISON , WI 53713

Pool Parameters	
Free Available Chlorine/Bromine	7.6
Combined Chlorine	0
pH	7.0
Alkalinity	80
Cyanuric Acid	<30
Temperature	78
Flowmeter Reading(s)	300
Pressure Gauges Reading(s)	14

Inspection Information		
Inspection Type Routine	Inspection Date June 12, 2018	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 12</p> <p>Observed Violations - 16 - pH alkalinity within limits or balanced, Cyanuric acid - within limits, Superoxidation - done as needed.</p> <p>OBSERVATION: The pH is 7.0.</p> <p>CORRECTIVE ACTION(S): Close the pool and do not reopen it until the pH falls between 7.2 and 7.8. Correct By: 13-Jun-2018</p> <p>CODE CITATION: ATCP 76.14 Disinfectant feeding and residuals. (4) CHEMICAL CONCENTRATIONS AND RESIDUALS. (a) Minimum disinfectant residuals. Except as provided in par. (b), feeding shall result in the minimum disinfectant residuals in Table ATCP 76.14.</p> <p>(c) pH control. The water's pH shall be maintained within a range of 7.2 to 7.8.</p> <p>Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted</p> <p>OBSERVATION: Safety is on site but not readily accessible.</p> <p>CORRECTIVE ACTION(S): Mount in a readily accessible location. Correct By: 12-Jun-2018</p> <p>CODE CITATION: ATCP 76.26 Rescue equipment. (1) REQUIRED EQUIPMENT. (a) All rescue equipment shall be maintained in good repair. Rescue equipment shall be mounted in a conspicuous place and shall be readily accessible.</p>

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: The safety rope is not in place.

CORRECTIVE ACTION(S): Put the safety rope in place and ensure that it stays in place during required times. Correct By: 13-Jun-2018

CODE CITATION: ATCP 76.26 Rescue equipment. (1) REQUIRED EQUIPMENT. (c) The safety rope required in s. SPS 390.18 (1) shall remain in place except during a lifeguarded activity or adult only lap swim. The responsible supervisor shall ensure the rope is in place during required times.

Observed Violations - 04 - Skimmers, gutters, drains, water inlets - number, clean, good repair, installed, operated

OBSERVATION: Skimmers, skimmer weirs, or overflow gutters are not clean.

CORRECTIVE ACTION(S): Maintain in a clean condition. Correct By: 13-Jun-2018

CODE CITATION: ATCP 76.11 Recirculation system. (2) (b) Skimmers, skimmer weirs, and overflow gutters and drains shall be maintained so that they are clean and shall be repaired or replaced as needed. Skimmer covers shall be securely seated on deck.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: The emergency telephone is not available.

CORRECTIVE ACTION(S): Provide a functional emergency telephone immediately. Correct By: 13-Jun-2018

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.02 (2).

Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.

OBSERVATION: "NO DIVING" is not posted in the pool rules.

CORRECTIVE ACTION(S): Post signage in compliance with ATCP 76.29(1)(c). Correct By: 12-Jun-2018

CODE CITATION: ATCP 76.29 Posting pool and water attraction rules. (1) GENERAL. (c) A pool that is 200 square feet in area or greater that does not have an approved diving well configuration shall have "NO DIVING" signs in at least 4-inch high letters included with the rules listed under par. (b).

Observed Violations - 29 - Facility maintenance and equipment - Pool and deck area - good repair, sanitation, maintained, depth markings, boundary line, drinking fountain

OBSERVATION: The drinking fountain is not functional.

CORRECTIVE ACTION(S): Repair the drinking fountain. Correct By: 12-Jun-2018

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (g) Drinking fountain. Each drinking fountain required under s. SPS 390.19 shall be maintained in clean and sanitary condition.

Observed Violations - 34 - Security - pool enclosure, controlled access, self-closing gates and latches access through bathhouse fencing safety rope as required.

OBSERVATION: The gate to the pool enclosure is not self-closing or latching and open.

CORRECTIVE ACTION(S): Repair the door immediately so that it is self-closing and latching or lock it. Correct By: 12-Jun-2018

CODE CITATION: ATCP 76.34 Pool design. (4) All pool areas shall be enclosed and have self-closing and latching gates or doors that are lockable.

Observed Violations - 34 - Security - pool enclosure, controlled access, self-closing gates and latches access through bathhouse fencing safety rope as required.

OBSERVATION: There is no sign on the premises that indicates that the pool is closed.

CORRECTIVE ACTION(S): Provide a sign that communicates to the public that the pool is closed. Correct By: 12-Jun-2018

CODE CITATION: ATCP 76.34 Pool design. (5) During closed hours, a sign shall be conspicuously posted stating that the pool, pool slide, water slide, or water attraction and deck are closed.

Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.

OBSERVATION: The sign for the rules is damaged and in need of replacement.

CORRECTIVE ACTION(S): Provide a sign in compliance with ATCP 76.29(1)(b). Correct By: 12-Jun-2018

CODE CITATION: ATCP 76.29 Posting pool and water attraction rules. (1) GENERAL. (b) A legible sign showing pool use rules shall be posted in a conspicuous place or places in the pool area. The sign shall include at least all of the rules in this paragraph in letters at least one inch high. Pool rules in connection with water attractions, therapy pools or other specialized pools defined in s. SPS 390 or this chapter may not be eliminated or modified without approval by the department.

1. Do not enter the pool if you have a communicable disease or an open cut.
2. Do not bring food, drink, gum or tobacco into the pool.
3. Shower before entering the pool and after use of toilet facilities.
4. Do not run or engage in rough play in the pool area.
5. Do not bring animals into the pool area.
6. Diaper changing on the pool deck is prohibited.
7. Glass and shatterable items are prohibited in the pool area.

Observed Violations - 25 - Lifeguards identifiable, no distracting duties, at duties station, certifications verified

OBSERVATION: Lifeguard training has not been completed.

CORRECTIVE ACTION(S): The lifeguard must be relieved of duties until a current certification can be verified. If the minimum lifeguard requirements in the approved staffing plan are not met as a result, the guarded pool or portion must be closed. Correct By: 12-Jun-2018

CODE CITATION: ATCP 76.22 Lifeguards and Attendants. (2) QUALIFICATIONS. (a) A copy of each lifeguarding certification, first aid certification, and CPR certification held by lifeguard staff shall be maintained at the pool and shall be made available for inspection by the department.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: The emergency numbers are not posted near the designated emergency phone.

CORRECTIVE ACTION(S): Post the emergency numbers near the designated emergency phone. Correct By: 13-Jun-2018

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.02 (2).

Comments:

VGBA approval 5/6/09. Grates were changed but no information available.

The Camp is working on compliance and is working on opening the pool.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



Sanitarian



Nicole Frankfourth
(608) 785-9731



Recreational Water Inspection Report

Establishment Information	
Facility Name CAMP EHAWEE	Facility Type Outdoor Pool
Facility ID # BSAW-86PHB8	Facility Telephone # 800 236-2710
Facility Address N9559 WILD RD MINDORO , WI 54644	
Licensee Name GIRL SCOUTS OF WISCONSIN-BADGERLAND INC	Licensee Address 2710 SKI LN MADISON , WI 53713

Pool Parameters	
Free Available Chlorine/Bromine	3.8
Combined Chlorine	0
pH	7.2
Alkalinity	80
Cyanuric Acid	
Temperature	80
Flowmeter Reading(s)	
Pressure Gauges Reading(s)	

Inspection Information		
Inspection Type Follow Up	Inspection Date June 20, 2018	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 10</p> <p>Observed Violations - 04 - Skimmers, gutters, drains, water inlets - number, clean, good repair, installed, operated OBSERVATION: The deep end skimmers are not adequately removing surface debris. Some skimmers had no flow noted and some weirs are also stuck. CORRECTIVE ACTION(S): Readjust the flow through the skimmers to maintain vigorous skimming action through all skimmers. Correct By: 20-Jun-2018 CODE CITATION: ATCP 76.11 Recirculation system. (2) SKIMMERS AND RECIRCULATION FLOW. (a) The flow through each skimmer shall be adjusted as often as necessary to maintain a vigorous skimming action at each skimmer. The pool water level shall be maintained at an elevation so that continuous effective surface skimming is accomplished through skimmers or over the gutter lip. For gutter pools, approximately 75% of the required recirculation flow shall be through the gutter and 25% through the main drain during normal operation. For pools with skimmers, approximately 80% of the recirculation flow shall be through skimmers and 20% through the main drain. For reverse flow pools, 100% of the required circulation shall be through the gutter or skimmer.</p> <p>Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted REPEAT OBSERVATION: Safety equipment is on site but not readily accessible. CORRECTIVE ACTION(S): Mount in a readily accessible location. Correct By: 12-Jun-2018</p>

CODE CITATION: ATCP 76.26 Rescue equipment. (1) REQUIRED EQUIPMENT. (a) All rescue equipment shall be maintained in good repair. Rescue equipment shall be mounted in a conspicuous place and shall be readily accessible.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

REPEAT OBSERVATION: The emergency telephone is not available.

CORRECTIVE ACTION(S): Provide a functional emergency telephone immediately. Correct By: 13-Jun-2018

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.02 (2).

Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.

REPEAT OBSERVATION: "NO DIVING" is not posted in the pool rules.

CORRECTIVE ACTION(S): Post signage in compliance with ATCP 76.29(1)(c). Correct By: 12-Jun-2018

CODE CITATION: ATCP 76.29 Posting pool and water attraction rules. (1) GENERAL. (c) A pool that is 200 square feet in area or greater that does not have an approved diving well configuration shall have "NO DIVING" signs in at least 4-inch high letters included with the rules listed under par. (b).

Observed Violations - 29 - Facility maintenance and equipment - Pool and deck area - good repair, sanitation, maintained, depth markings, boundary line, drinking fountain

REPEAT OBSERVATION: The drinking fountain is not functional.

CORRECTIVE ACTION(S): Repair the drinking fountain. Correct By: 12-Jun-2018

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (g) Drinking fountain. Each drinking fountain required under s. SPS 390.19 shall be maintained in clean and sanitary condition.

Observed Violations - 34 - Security - pool enclosure, controlled access, self-closing gates and latches access through bathhouse fencing safety rope as required.

REPEAT OBSERVATION: The gate to the pool enclosure is not self-closing or latching and open.

CORRECTIVE ACTION(S): Repair the door immediately so that it is self-closing and latching or lock it. Correct By: 12-Jun-2018

CODE CITATION: ATCP 76.34 Pool design. (4) All pool areas shall be enclosed and have self-closing and latching gates or doors that are lockable.

Observed Violations - 34 - Security - pool enclosure, controlled access, self-closing gates and latches access through bathhouse fencing safety rope as required.

REPEAT OBSERVATION: There is no sign on the premises that indicates that the pool is closed.

CORRECTIVE ACTION(S): Provide a sign that communicates to the public that the pool is closed. Correct By: 12-Jun-2018

CODE CITATION: ATCP 76.34 Pool design. (5) During closed hours, a sign shall be conspicuously posted stating that the pool, pool slide, water slide, or water attraction and deck are closed.

Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.

REPEAT OBSERVATION: The sign for the rules is damaged and in need of replacement.

CORRECTIVE ACTION(S): Provide a sign in compliance with ATCP 76.29(1)(b). Correct By: 12-Jun-2018

CODE CITATION: ATCP 76.29 Posting pool and water attraction rules. (1) GENERAL. (b) A legible sign showing pool use rules shall be posted in a conspicuous place or places in the pool area. The sign shall include at least all of the rules in this paragraph in letters at least one inch high. Pool rules in connection with water attractions, therapy pools or other specialized pools defined in s. SPS 390 or this chapter may not be eliminated or modified without approval by the department.

1. Do not enter the pool if you have a communicable disease or an open cut.
2. Do not bring food, drink, gum or tobacco into the pool.
3. Shower before entering the pool and after use of toilet facilities.
4. Do not run or engage in rough play in the pool area.
5. Do not bring animals into the pool area.
6. Diaper changing on the pool deck is prohibited.
7. Glass and shatterable items are prohibited in the pool area.

Observed Violations - 25 - Lifeguards identifiable, no distracting duties, at duties station, certifications verified

REPEAT OBSERVATION: Lifeguard training has not been completed.

CORRECTIVE ACTION(S): The lifeguard must be relieved of duties until a current certification can be verified. If the minimum lifeguard requirements in the approved staffing plan are not met as a result, the guarded pool or portion must be closed. Correct By: 12-Jun-2018

CODE CITATION: ATCP 76.22 Lifeguards and Attendants. (2) QUALIFICATIONS. (a) A copy of each lifeguarding certification, first aid certification, and CPR certification held by lifeguard staff shall be maintained at the pool and shall be made available for inspection by the department.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

REPEAT OBSERVATION: The emergency numbers are not posted near the designated emergency phone.

CORRECTIVE ACTION(S): Post the emergency numbers near the designated emergency phone. Correct By: 13-Jun-2018

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.02 (2).

Corrected Hazards

The following hazard(s) have been corrected since the last inspection.

Total # 2

ATCP 76.14(4)(c) - pH OUT OF BALANCE

OBSERVATION: The pH is 7.0.

CORRECTIVE ACTION(S): Close the pool and do not reopen it until the pH falls between 7.2 and 7.8. Correct By: 13-Jun-2018

CODE CITATION: ATCP 76.14 Disinfectant feeding and residuals. (4) CHEMICAL CONCENTRATIONS AND RESIDUALS. (a) Minimum disinfectant residuals. Except as provided in par. (b), feeding shall result in the minimum disinfectant residuals in Table ATCP 76.14.

(c) pH control. The water's pH shall be maintained within a range of 7.2 to 7.8.

ATCP 76.26(1)(c) - SAFETY ROPE NOT IN PLACE

OBSERVATION: The safety rope is not in place.

CORRECTIVE ACTION(S): Put the safety rope in place and ensure that it stays in place during required times. Correct By: 13-Jun-2018

CODE CITATION: ATCP 76.26 Rescue equipment. (1) REQUIRED EQUIPMENT. (c) The safety rope required in s. SPS 390.18 (1) shall remain in place except during a lifeguarded activity or adult only lap swim. The responsible supervisor shall ensure the rope is in place during required times.


Comments:

[Reinspection scheduled for Thursday 6/21/18 after 3:00. Fee applies.](#)

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian



Lori Asstell



Doug Schaefer
(608) 785-9679