



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name FAIRFIELD INN & SUITES LA CROSSE DOWNTOWN	Facility Type Indoor Pool
Facility ID # ASTS-A9PK4U	Facility Telephone # 608 782-1491
Facility Address 434 S 3RD ST LA CROSSE , WI 54601	
Licensee Name 434 HOLDINGS	Licensee Address 434 S 3RD ST LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	2.0
Combined Chlorine	1.0
pH	7.8
Alkalinity	90
Cyanuric Acid	NA
Temperature	86
Flowmeter Reading(s)	55
Pressure Gauges Reading(s)	20

Inspection Information		
Inspection Type Routine	Inspection Date January 11, 2018	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 1</p> <p>Observed Violations - 16 - pH alkalinity within limits or balanced, Cyanuric acid - within limits, Superoxidation - done as needed.</p> <p>OBSERVATION: (CORRECTED DURING INSPECTION): The combined chlorine is 1.0.</p> <p>CORRECTIVE ACTION(S): Treat the pool with breakpoint chlorination using a chlorine product or a nonchlorinated oxidizer. Correct By: 11-Jan-2018</p> <p>CODE CITATION: ATCP 76.14 Disinfectant feeding and residuals. (4) CHEMICAL CONCENTRATIONS AND RESIDUALS. (e) Combined chlorine. When combined chlorine exceeds 0.5 ppm in an outdoor pool or 0.8 ppm in an indoor pool, the water shall be treated to breakpoint chlorination using a chlorine product or a nonchlorinated oxidizer such as potassium peroxydisulfate. Isocyanurates may not be used to reach breakpoint chlorination. The pool shall be closed to the public during periods of breakpoint chlorination when a chlorine product is used.</p>

Comments:
VGBA paperwork is required to keep on file. Re-inspection in one week.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

A re-inspection to assess your correction of these violations will be conducted on, or about, 01/18/2018

Person in Charge



Sanitarian



Aron Newberry
(608) 785-9730



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name FAIRFIELD INN & SUITES LA CROSSE DOWNTOWN	Facility Type Indoor Pool
Facility ID # ASTS-A9PK4U	Facility Telephone # 608 782-1491
Facility Address 434 S 3RD ST LA CROSSE , WI 54601	
Licensee Name 434 HOLDINGS	Licensee Address 434 S 3RD ST LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	2.0
Combined Chlorine	1.0
pH	7.8
Alkalinity	90
Cyanuric Acid	NA
Temperature	86
Flowmeter Reading(s)	55
Pressure Gauges Reading(s)	20

Inspection Information		
Inspection Type Routine	Inspection Date January 11, 2018	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 1</p> <p>Observed Violations - 16 - pH alkalinity within limits or balanced, Cyanuric acid - within limits, Superoxidation - done as needed.</p> <p>OBSERVATION: (CORRECTED DURING INSPECTION): The combined chlorine is 1.0.</p> <p>CORRECTIVE ACTION(S): Treat the pool with breakpoint chlorination using a chlorine product or a nonchlorinated oxidizer. Correct By: 11-Jan-2018</p> <p>CODE CITATION: ATCP 76.14 Disinfectant feeding and residuals. (4) CHEMICAL CONCENTRATIONS AND RESIDUALS. (e) Combined chlorine. When combined chlorine exceeds 0.5 ppm in an outdoor pool or 0.8 ppm in an indoor pool, the water shall be treated to breakpoint chlorination using a chlorine product or a nonchlorinated oxidizer such as potassium peroxydisulfate. Isocyanurates may not be used to reach breakpoint chlorination. The pool shall be closed to the public during periods of breakpoint chlorination when a chlorine product is used.</p>

Comments:
VGBA paperwork is required to keep on file. Re-inspection in one week.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

A re-inspection to assess your correction of these violations will be conducted on, or about, 01/18/2018

Person in Charge



Sanitarian



Aron Newberry
(608) 785-9730