



Recreational Water Inspection Report

Establishment Information	
Facility Name GRANDSTAY RESIDENTIAL SUITES	Facility Type Indoor Pool
Facility ID # HSAT-7QXMS6	Facility Telephone # 608 796-1615
Facility Address SWIMMING POOL 525 FRONT STREET N LA CROSSE , WI 54601	
Licensee Name GRANDSTAY HOTEL & SUITES	Licensee Address 525 FRONT STREET N ST LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	6.2
Combined Chlorine	0
Oxidation Reduction Potential	
Disinfectant Type	Chlorine-Liquid
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	7.4
Alkalinity	160
Cyanuric Acid	
Temperature	83
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	55
Pressure Gauges Reading(s)	18
Turnover Rate	

Inspection Information		
Inspection Type Routine	Inspection Date January 15, 2019	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Comments:
Samples collected.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian

Terri Gregory

Aron Newberry
(608) 785-9730



Recreational Water Inspection Report

Establishment Information	
Facility Name GRANDSTAY RESIDENTIAL SUITES	Facility Type Additional Indoor Pool
Facility ID # HSAT-7QWHAK	Facility Telephone # 608 796-1615
Facility Address WHIRLPOOL 525 FRONT STREET N LA CROSSE , WI 54601	
Licensee Name GRANDSTAY HOTEL & SUITES	Licensee Address 525 FRONT STREET N ST LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	7.4
Combined Chlorine	.2
Oxidation Reduction Potential	
Disinfectant Type	Chlorine-Liquid
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	7.4
Alkalinity	140
Cyanuric Acid	
Temperature	103
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	45
Pressure Gauges Reading(s)	20
Turnover Rate	


Inspection Information		
Inspection Type Routine	Inspection Date January 15, 2019	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Comments:
Samples collected.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



Terri Gregory

Sanitarian



Aron Newberry
(608) 785-9730