



Recreational Water Inspection Report

Establishment Information	
Facility Name GUNDERSEN HOTEL & SUITES	Facility Type Indoor Pool
Facility ID # CDRY-AQ4RZ9	Facility Telephone # 608 793-0200
Facility Address 1520 CLINIC CT LA CROSSE , WI 54601	
Licensee Name SELECT LA CROSSE, LLC	Licensee Address 1520 CLINIC CT LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	3.0
Combined Chlorine	.8
Oxidation Reduction Potential	
Disinfectant Type	Chlorine-Liquid
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	7.2
Alkalinity	.5
Cyanuric Acid	
Temperature	87
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	70
Pressure Gauges Reading(s)	8
Turnover Rate	

Inspection Information		
Inspection Type Routine	Inspection Date January 8, 2019	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations

Total # 2

Observed Violations - 16 - pH alkalinity within limits or balanced, Cyanuric acid - within limits, Superoxidation - done as needed.

OBSERVATION: The total alkalinity is 50.

CORRECTIVE ACTION(S): Maintain the total alkalinity between 60 and 180 ppm. Correct By: 08-Jan-2019

CODE CITATION: ATCP 76.14 Disinfectant feeding and residuals. (4) CHEMICAL CONCENTRATIONS AND RESIDUALS. (d) Alkalinity. The total alkalinity of pool water shall be maintained between 60 and 180 ppm as calcium carbonate unless it can be shown that another level of total alkalinity produces chemically balanced water based on calculations approved by the department.

Observed Violations - 20 - Approved test kits available, maintained, used, frequency of testing - 2X/day-pools, 4x/day-whirlpools alkalinity, cyanuric acid, and combined chlorine done as required.

OBSERVATION: The water testing frequency for total alkalinity is not in compliance with ATCP 76.18(1).

CORRECTIVE ACTION(S): Perform total alkalinity test 1x/week. Perform water testing in accordance with ATCP 76.18(1). Correct By: 08-Jan-2019

CODE CITATION: ATCP 76.18 Water testing frequency. (1) Except as provided under sub. (2) or (3), water shall be tested for pH and disinfectant residual daily before the pool is open to the public or before the pool is in use, and at least one other time during the day's peak patron load. When chlorine is used, the water shall also be tested at least twice a week for the combined chlorine level. Water shall also be tested at least once a week for total alkalinity. When cyanuric acid is used in the water basin, the cyanuric acid concentration in the water shall be tested at least once a week.

Comments:

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



gretchen henchen

Sanitarian



**Aron Newberry
(608) 785-9730**