



### Recreational Water Inspection Report

<b>Establishment Information</b>	
Facility Name <b>HAMPTON INN &amp; SUITES</b>	Facility Type <b>Indoor Pool</b>
Facility ID # <b>ASTS-A2KQ9A</b>	Facility Telephone # <b>608</b>
Facility Address <b>511 N 3RD ST LA CROSSE , WI 54601</b>	
Licensee Name <b>LA CROSSE HOTEL GROUP LLC</b>	Licensee Address <b>511 N 3RS ST LA CROSSE , WI 54601</b>

<b>Pool Parameters</b>	
Free Available Chlorine/Bromine	5.2
Combined Chlorine	0.4
Oxidation Reduction Potential	713
Disinfectant Type	Chlorine-Liquid
Secondary Disinfectant Type	Chlorine Generated-Salt
Secondary Disinfectant Level	
pH	7.2
Alkalinity	80
Cyanuric Acid	
Temperature	86.4
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	70
Pressure Gauges Reading(s)	18
Turnover Rate	4.87

<b>Inspection Information</b>		
Inspection Type Routine	Inspection Date January 29, 2020	Total Time Spent

**OPERATOR** - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

<b>Comments:</b>
<a href="#">VGBA expires 12/18/20</a> <a href="#">No violations during inspection</a>

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian



vince



Amanda Ramos  
(608) 785-9771