



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name HOLIDAY INN	Facility Type Indoor Pool
Facility ID # HSAT-7QWF4M	Facility Telephone # 608 784-4444
Facility Address 200 PEARL STREET INDOOR SWIMMING POOL LA CROSSE , WI 54601	
Licensee Name PEARL STREET ENTERPRISE INC	Licensee Address 200 PEARL ST LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	11
Combined Chlorine	NA
pH	7.4
Alkalinity	70
Cyanuric Acid	NA
Temperature	80.6
Flowmeter Reading(s)	80
Pressure Gauges Reading(s)	30

Inspection Information		
Inspection Type Routine	Inspection Date January 12, 2018	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations

Total # 5

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: Biohazard safety kit is incomplete, and therefore unavailable.

CORRECTIVE ACTION(S): Provide a biohazard safety kit at the first aid station. Correct By: 05-Feb-2018

CODE CITATION: ATCP 76.27 First aid supplies. (2) Biohazard safety equipment, including a blood and biohazard disposal kit shall be located at the first aid station or another location on the premises approved by the department.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: A first aid kit is not available in the pool area.

CORRECTIVE ACTION(S): Provide a first aid kit in the pool area. Correct By: 12-Jan-2018

CODE CITATION: ATCP 76.27 First aid supplies. (1) A first aid kit of a sort approved by the department and 2 durable blankets in good condition shall be available at each pool area. The first aid kit shall contain all of the following items:

1. Gauze pads - 4" x 4", 2. Gauze pads - 8" x 10", 3. Adhesive bandages, 4. Triangular bandages, 5. Scissors, 6. Gauze roller bandage, 7. Tweezers, 8. Adhesive tape, 9. Eye wash, 10. Elastic bandage, 11. Disposable surgical gloves, 12. Resuscitation pocket face mask, 13. Instant cold packs.

Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.

OBSERVATION: The letters on the pool rules signage are less than 1-inch in height. The capital letters are 1" but the lowercase letters are currently only 3/4 inch high.

CORRECTIVE ACTION(S): Reprint the sign in compliance with ATCP 76.29(1)(b). Correct By: 12-Feb-2018

CODE CITATION: ATCP 76.29 Posting pool and water attraction rules. (1) GENERAL. (b) A legible sign showing pool use rules shall be posted in a conspicuous place or places in the pool area. The sign shall include at least all of the rules in this paragraph in letters at least one inch high. Pool rules in connection with water attractions, therapy pools or other specialized pools defined in s. Comm 90 or this chapter may not be eliminated or modified without approval by the department.

1. Do not enter the pool if you have a communicable disease or an open cut.
2. Do not bring food, drink, gum or tobacco into the pool.
3. Shower before entering the pool and after use of toilet facilities.
4. Do not run or engage in rough play in the pool area.
5. Do not bring animals into the pool area.
6. Diaper changing on the pool deck is prohibited.
7. Glass and shatterable items are prohibited in the pool area.

Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.

OBSERVATION: "NO DIVING" is not posted in the pool rules.

CORRECTIVE ACTION(S): Post signage in compliance with ATCP 76.29(1)(c). Correct By: 12-Feb-2018

CODE CITATION: ATCP 76.29 Posting pool and water attraction rules. (1) GENERAL. (c) A pool that is 200 square feet in area or greater that does not have an approved diving well configuration shall have "NO DIVING" signs in at least 4-inch high letters included with the rules listed under par. (b).

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: Tweezers, adhesive tape, elastic bandage, resuscitation pocket face mask, and instant cold packs are missing from the first aid kit.

CORRECTIVE ACTION(S): Provide all the items listed in ATCP 76.27(1) in the first aid kit. Correct By: 12-Jan-2018

CODE CITATION: ATCP 76.27 First aid supplies. (1) A first aid kit of a sort approved by the department and 2 durable blankets in good condition shall be available at each pool area. The first aid kit shall contain all of the following items:

1. Gauze pads - 4" x 4", 2. Gauze pads - 8" x 10", 3. Adhesive bandages, 4. Triangular bandages, 5. Scissors, 6. Gauze roller bandage, 7. Tweezers, 8. Adhesive tape, 9. Eye wash, 10. Elastic bandage, 11. Disposable surgical gloves, 12. Resuscitation pocket face mask, 13. Instant cold packs.

Comments:

Missing up to date VGBA drain information and install date, reinspection in 1 week. .
Keep D-I-I form on file.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

A re-inspection to assess your correction of these violations will be conducted on, or about, 01/12/2018

Person in Charge

Sanitarian



Katrina Curry



Aron Newberry
(608) 785-9730



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name HOLIDAY INN	Facility Type Additional Indoor Pool
Facility ID # HSAT-7QX6CT	Facility Telephone # 608 784-4444
Facility Address 200 PEARL STREET INDOOR WHIRLPOOL LA CROSSE , WI 54601	
Licensee Name PEARL STREET ENTERPRISE INC	Licensee Address 200 PEARL ST LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	12
Combined Chlorine	NA
pH	7.4
Alkalinity	110
Cyanuric Acid	NA
Temperature	100
Flowmeter Reading(s)	50
Pressure Gauges Reading(s)	25

Inspection Information		
Inspection Type Routine	Inspection Date January 12, 2018	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 1</p> <p>Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.</p> <p>OBSERVATION: The letters on the pool rules signage are less than 1-inch in height.</p> <p>CORRECTIVE ACTION(S): Reprint the sign in compliance with ATCP 76.29(1)(b). Correct By: 12-Feb-2018</p> <p>CODE CITATION: ATCP 76.29 Posting pool and water attraction rules. (1) GENERAL. (b) A legible sign showing pool use rules shall be posted in a conspicuous place or places in the pool area. The sign shall include at least all of the rules in this paragraph in letters at least one inch high. Pool rules in connection with water attractions, therapy pools or other specialized pools defined in s. Comm 90 or this chapter may not be eliminated or modified without approval by the department.</p> <ol style="list-style-type: none"> Do not enter the pool if you have a communicable disease or an open cut. Do not bring food, drink, gum or tobacco into the pool. Shower before entering the pool and after use of toilet facilities. Do not run or engage in rough play in the pool area. Do not bring animals into the pool area. Diaper changing on the pool deck is prohibited. Glass and shatterable items are prohibited in the pool area.

Comments:

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

A re-inspection to assess your correction of these violations will be conducted on, or about, 02/12/2018

Person in Charge



Katrina Curry

Sanitarian



Aron Newberry
(608) 785-9730