



Recreational Water Establishment Inspection Report

| Establishment Information | |
|---|--|
| Facility Name HOME2 SUITES BY HILTON LA CROSSE | Facility Type Indoor Pool |
| Facility ID # ASTS-ABBS7E | Facility Telephone # 608 |
| Facility Address 210 JAY ST LA CROSSE, WI 54601 | |
| Licensee Name 210 JAY ST LLC | Licensee Address 210 JAY ST LA CROSSE, WI 54601 |

| Pool Parameters | |
|---------------------------------|------|
| Free Available Chlorine/Bromine | 2.2 |
| Combined Chlorine | .4 |
| pH | 7.6 |
| Alkalinity | |
| Cyanuric Acid | |
| Temperature | 79.3 |
| Flowmeter Reading(s) | 60 |
| Pressure Gauges Reading(s) | 25 |

| Inspection Information | | |
|-------------------------------|-------------------------------|------------------|
| Inspection Type Routine | Inspection Date 10/24/2016 | Total Time Spent |

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations

Total # 3

Observed Violations - 20 - Approved test kits available, maintained, used, frequency of testing - 2X/day-pools, 4x/day-whirlpools alkalinity, cyanuric acid, and combined chlorine done as required.

OBSERVATION: The water testing frequency for combined chlorine is not in compliance with ATCP 76.18(1).

CORRECTIVE ACTION(S): Test for combines chlorine twice a week, and record on the daily monitoing chart. Perform water testing in accordance with ATCP 76.18(1). Correct By: 24-Oct-2016

CODE CITATION: ATCP 76.18 Water testing frequency. (1) Except as provided under sub. (2) or (3), water shall be tested for pH and disinfectant residual daily before the pool is open to the public or before the pool is in use, and at least one other time during the day's peak patron load. When chlorine is used, the water shall also be tested at least twice a week for the combined chlorine level. Water shall also be tested at least once a week for total alkalinity. When cyanuric acid is used in the water basin, the cyanuric acid concentration in the water shall be tested at least once a week.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: 2 durable blankets are not available in the pool area.

CORRECTIVE ACTION(S): Provide 2 durable blankets in the pool area. Correct By: 31-Oct-2016

CODE CITATION: ATCP 76.27 First aid supplies. (1) A first aid kit of a sort approved by the department and 2 durable blankets in good condition shall be available at each pool area. The first aid kit shall contain all of the following items:

1. Gauze pads - 4" x 4", 2. Gauze pads - 8" x 10", 3. Adhesive bandages, 4. Triangular bandages, 5. Scissors, 6. Gauze roller bandage, 7. Tweezers, 8. Adhesive tape, 9. Eye wash, 10. Elastic bandage, 11. Disposable surgical gloves, 12. Resuscitation pocket face mask, 13. Instant cold packs.

Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.

OBSERVATION: Post the pool generic pool rules on the wall, and reference ATCP 76.29(1)(b) when creating a custom sign.

CORRECTIVE ACTION(S): Provide a sign in compliance with ATCP 76.29(1)(b). Correct By: 24-Oct-2016

CODE CITATION: ATCP 76.29 Posting pool and water attraction rules. (1) GENERAL. (b) A legible sign showing pool use rules shall be posted in a conspicuous place or places in the pool area. The sign shall include at least all of the rules in this paragraph in letters at least one inch high. Pool rules in connection with water attractions, therapy pools or other specialized pools defined in s. SPS 390 or this chapter may not be eliminated or modified without approval by the department.

1. Do not enter the pool if you have a communicable disease or an open cut.
2. Do not bring food, drink, gum or tobacco into the pool.
3. Shower before entering the pool and after use of toilet facilities.
4. Do not run or engage in rough play in the pool area.
5. Do not bring animals into the pool area.
6. Diaper changing on the pool deck is prohibited.
7. Glass and shatterable items are prohibited in the pool area.

Comments

[Store first aid kit and blankets in plain sight inside the pool area.](#)

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

A re-inspection to assess your correction of these violations will be conducted on, or about, 10/31/2016

Person in Charge



Julian Bene

Sanitarian



Aron Newberry
(608) 785-9730