



Recreational Water Inspection Report

Establishment Information	
Facility Name MITCHELL HALL	Facility Type Indoor Pool
Facility ID # HSAT-7QXE2S	Facility Telephone # 608 317-2183
Facility Address 1820 PINE ST LA CROSSE , WI 54601	
Licensee Name UW LA CROSSE	Licensee Address 855 E AVENUE N LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	3.0
Combined Chlorine	0.0
Oxidation Reduction Potential	817
Disinfectant Type	Chlorine-Erosion
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	7.4
Alkalinity	60
Cyanuric Acid	
Temperature	81
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	650
Pressure Gauges Reading(s)	
Turnover Rate	4.6

Inspection Information		
Inspection Type Routine	Inspection Date June 24, 2019	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 1</p> <p>Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted This is a Critical violation OBSERVATION: (CORRECTED DURING INSPECTION): The sheperd's crook is on site but not readily accessible. CORRECTIVE ACTION(S): Mount sheperd's crook in a readily accessible location. CODE CITATION: ATCP 76.26 Rescue equipment. (1) REQUIRED EQUIPMENT. (a) All rescue equipment shall be maintained in good repair. Rescue equipment shall be mounted in a conspicuous place and shall be readily accessible.</p>

Comments:

Contact Sam (785-9732) with questions.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



Scott Brown

Sanitarian



Samuel Welch
(608) 785-9732