



Recreational Water Inspection Report

Establishment Information	
Facility Name RADISSON LA CROSSE HOTEL	Facility Type Indoor Pool
Facility ID # HSAT-7QWGY2	Facility Telephone # 608
Facility Address 200 HARBORVIEW PLAZA LA CROSSE , WI 54601	
Licensee Name R L H CORP	Licensee Address 200 HARBORVIEW PLAZA LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	3.4
Combined Chlorine	0.6
Oxidation Reduction Potential	N/A
Disinfectant Type	Chlorine-Liquid
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	7.4
Alkalinity	90
Cyanuric Acid	
Temperature	87.5
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	97
Pressure Gauges Reading(s)	
Turnover Rate	3.56

Inspection Information		
Inspection Type Routine	Inspection Date January 28, 2020	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Comments:
No violations at time of inspection

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian

gary

Amanda Ramos
(608) 785-9771



Recreational Water Inspection Report

Establishment Information	
Facility Name RADISSON LA CROSSE HOTEL	Facility Type Additional Indoor Pool
Facility ID # HSAT-7QXK4E	Facility Telephone #
Facility Address 200 HARBORVIEW PLAZA LA CROSSE , WI 54601	
Licensee Name R L H CORP	Licensee Address 200 HARBORVIEW PLAZA LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	3.0
Combined Chlorine	0.4
Oxidation Reduction Potential	726
Disinfectant Type	Chlorine-Liquid
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	7.2
Alkalinity	130
Cyanuric Acid	
Temperature	102.9
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	48
Pressure Gauges Reading(s)	
Turnover Rate	0.35

Inspection Information		
Inspection Type Routine	Inspection Date January 28, 2020	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Comments:
No violations at time of inspection


Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



gary

Sanitarian



Amanda Ramos
(608) 785-9771