



Recreational Water Inspection Report

Establishment Information	
Facility Name STONEY CREEK INN	Facility Type Indoor Pool
Facility ID # HSAT-7QWJS3	Facility Telephone # 608 781-3060
Facility Address 3060 KINNEY COULEE RD S ONALASKA , WI 54650	
Licensee Name STONEY CREEK INVESTORS OF LA CROSSE	Licensee Address 3060 KINNEY COULEE ROAD S ONALASKA , WI 54650

Pool Parameters	
Free Available Chlorine/Bromine	9.4
Combined Chlorine	0.4
Oxidation Reduction Potential	820
Disinfectant Type	Chlorine-Liquid
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	7.2
Alkalinity	90
Cyanuric Acid	
Temperature	83.5
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	not working
Pressure Gauges Reading(s)	18
Turnover Rate	--

Inspection Information		
Inspection Type Routine	Inspection Date January 16, 2020	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations

Total # 2

Observed Violations - 09 - Gauges and flowmeters maintained, operated, accurate, installed, approved pressure or vacuum

REPEAT OBSERVATION: The flowmeter for the main pool is not operating.

CORRECTIVE ACTION(S): Repair or replace the specified equipment so an accurate reading can be recorded. Correct By: 16-Feb-2020

CODE CITATION: ATCP 76.11 Recirculation system. (5) FLOWMETERS, VALVES, AND GAUGES. Flowmeters, valves and gauges shall be maintained in operating condition.

Observed Violations - 28 - Fecal accident records, D-I-I reporting as required, and other reports as required, maintained, accurate, and accessible.

OBSERVATION: Manufacturer's pump performance curve is not available for review.

CORRECTIVE ACTION(S): Keep records in accordance with ATCP 76.32(3). Correct By: 16-Jan-2020

CODE CITATION: ATCP 76.32 Monthly reports and records. (3) FILES. (a) The operator shall maintain on the premises a file containing a copy of each of the following:

1. The monthly operating reports required under sub. (1).
 2. Each laboratory bacteriological report.
 3. Each fecal accident report made under s. ATCP 76.31.
 4. In addition to the reports listed under subs. 1., 2., and 3. any other report submitted to the department or agent for the preceding 2 year period.
 5. A copy of the most current version of ch. ATCP 76.
 6. Pool construction plans.
 7. The manufacturer's pump performance curve, manual of instruction on filter operation, recommendations for operation and maintenance of all equipment, and instructions and other pertinent information on pool operation and maintenance.
 8. The most recent Federal centers for disease control recommendations for fecal accidents or other plan in response to fecal accidents.
 9. Daily inspections and operational tests as specified in s. ATCP 76.37.
- (b) All records shall be kept at least 7 years, except that monthly reports, fecal accident reports, daily inspection results, and operational tests shall be kept for at least 2 years.
- (c) All of the documents under par. (a) shall be accessible to the operator and the department or agent.

Comments:

[VGBA documents in compliance](#)

[AR to send flowmeter info](#)

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian

jonathan

Amanda Ramos
(608) 785-9771



Recreational Water Inspection Report

Establishment Information	
Facility Name STONEY CREEK INN	Facility Type Additional Indoor Pool
Facility ID # HSAT-7QWGXB	Facility Telephone # 608 781-3060
Facility Address 3060 KINNEY COULEE RD S ONALASKA , WI 54650	
Licensee Name STONEY CREEK INVESTORS OF LA CROSSE	Licensee Address 3060 KINNEY COULEE ROAD S ONALASKA , WI 54650

Pool Parameters	
Free Available Chlorine/Bromine	5.2
Combined Chlorine	.2
Oxidation Reduction Potential	781
Disinfectant Type	Chlorine-Liquid
Secondary Disinfectant Type	
Secondary Disinfectant Level	
pH	7.2
Alkalinity	40
Cyanuric Acid	
Temperature	101
Calcium Hardness	
Saturation Index	
Flowmeter Reading(s)	200
Pressure Gauges Reading(s)	18
Turnover Rate	.5

Inspection Information		
Inspection Type Routine	Inspection Date January 16, 2020	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 1</p> <p>Observed Violations - 16 - pH alkalinity within limits or balanced, Cyanuric acid - within limits, Superoxidation - done as needed.</p> <p>REPEAT OBSERVATION: The total alkalinity is 40.</p> <p>CORRECTIVE ACTION(S): Maintain the total alkalinity between 60 and 180 ppm. Correct By: 16-Jan-2020</p> <p>CODE CITATION: ATCP 76.14 Disinfectant feeding and residuals. (4) CHEMICAL CONCENTRATIONS AND RESIDUALS. (d) Alkalinity. The total alkalinity of pool water shall be maintained between 60 and 180 ppm as calcium carbonate unless it can be shown that another level of total alkalinity produces chemically balanced water based on calculations approved by the department.</p>

Comments:

[VGBA documents in compliance](#)

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



jonathan

Sanitarian



Amanda Ramos
(608) 785-9771