



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name WITTICH HALL	Facility Type Indoor Pool
Facility ID # HSAT-7QWDD8	Facility Telephone # 608 785-8912
Facility Address 1710 PINE ST LA CROSSE , WI 54601	
Licensee Name UW LA CROSSE	Licensee Address 1725 STATE ST LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	3.5
Combined Chlorine	.2
pH	7.4
Alkalinity	50
Cyanuric Acid	
Temperature	87.8
Flowmeter Reading(s)	100
Pressure Gauges Reading(s)	20

Inspection Information		
Inspection Type Routine	Inspection Date 01/22/2014	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 5</p> <p>Observed Violations - 16 - pH alkalinity within limits or balanced, Cyanuric acid - within limits, Superoxidation - done as needed. OBSERVATION: The total alkalinity is 50ppm's. CORRECTIVE ACTION(S): Maintain the total alkalinity between 60 and 180 ppm. Correct By: 23-Jan-2014 CODE CITATION: DHS 172.14 Disinfectant feeding and residuals. (4) CHEMICAL CONCENTRATIONS AND RESIDUALS. (d) Alkalinity. The total alkalinity of pool water shall be maintained between 60 and 180 ppm as calcium carbonate unless it can be shown that another level of total alkalinity produces chemically balanced water based on calculations approved by the department.</p> <p>Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted OBSERVATION: 2 durable blankets are not available in the pool area. CORRECTIVE ACTION(S): Provide 2 durable blankets in the pool area. Correct By: 04-Feb-2014</p>

CODE CITATION: DHS 172.27 First aid supplies. (1) A first aid kit of a sort approved by the department and 2 durable blankets in good condition shall be available at each pool area. The first aid kit shall contain all of the following items:

1. Gauze pads - 4" x 4",
2. Gauze pads – 8" x 10",
3. Adhesive bandages,
4. Triangular bandages,
5. Scissors,
6. Gauze roller bandage,
7. Tweezers,
8. Adhesive tape,
9. Eye wash,
10. Elastic bandage,
11. Disposable surgical gloves,
12. Resuscitation pocket face mask,
13. Instant cold packs.

Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.

OBSERVATION: The following rules are missing from the posting: Diaper Changing on the deck is prohibited..

CORRECTIVE ACTION(S): Provide a sign in compliance with DHS 172.29(1)(b). Correct By: 04-Feb-2014

CODE CITATION: DHS 172.29 Posting pool and water attraction rules. (1) GENERAL. (b) A legible sign showing pool use rules shall be posted in a conspicuous place or places in the pool area. The sign shall include at least all of the rules in this paragraph in letters at least one inch high. Pool rules in connection with water attractions, therapy pools or other specialized pools defined in s. Comm 90 or this chapter may not be eliminated or modified without approval by the department.

1. Do not enter the pool if you have a communicable disease or an open cut.
2. Do not bring food, drink, gum or tobacco into the pool.
3. Shower before entering the pool and after use of toilet facilities.
4. Do not run or engage in rough play in the pool area.
5. Do not bring animals into the pool area.
6. Diaper changing on the pool deck is prohibited.
7. Glass and shatterable items are prohibited in the pool area.

Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.

OBSERVATION: The letters on the pool rules signage are less than 1-inch in height. The signs need to be replaced with code compliant signs

CORRECTIVE ACTION(S): Reprint the sign in compliance with DHS 172.29(1)(b). Correct By: 04-Feb-2014

CODE CITATION: DHS 172.29 Posting pool and water attraction rules. (1) GENERAL. (b) A legible sign showing pool use rules shall be posted in a conspicuous place or places in the pool area. The sign shall include at least all of the rules in this paragraph in letters at least one inch high. Pool rules in connection with water attractions, therapy pools or other specialized pools defined in s. Comm 90 or this chapter may not be eliminated or modified without approval by the department.

1. Do not enter the pool if you have a communicable disease or an open cut.
2. Do not bring food, drink, gum or tobacco into the pool.
3. Shower before entering the pool and after use of toilet facilities.
4. Do not run or engage in rough play in the pool area.
5. Do not bring animals into the pool area.
6. Diaper changing on the pool deck is prohibited.
7. Glass and shatterable items are prohibited in the pool area.

Observed Violations - 30 - Toilet, shower, dressing rooms, provided as needed, clean maintained, hand drying, toilet tissue, suits, caps, or towels provided to patrons - clean, thoroughly laundered, storage

REPEAT OBSERVATION: The soap dispensers in the men's locker room were missing .

CORRECTIVE ACTION(S): Provide soap at all hand washing sinks and showers. Correct By: 04-Feb-2014

CODE CITATION: DHS 172.33 Facility maintenance, repair and sanitation. (2) SHOWER, TOILET AND DRESSING FACILITIES. (e) Soap shall be continually provided at each hand washing sink and shower in permanently installed dispensing devices. The dispensers shall be maintained in operating condition.

Comments

Most of the items listed on the inspection are existing problems that have been written-up before. I will be checking for compliance during the February monthly inspection.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



Tom Nyre

Sanitarian



David Sawvell
(608) 785-9726